



EU-type examination certificate

Number **T10805** revision 6
Project number 3984836
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Shenzhen Kaifa Technology (Chengdu) Co., Ltd.
No. 99 Tianquan Rd.,
Hi-Tech Development Zone,
Chengdu, (PC: 611731),
P.R. China

Measuring instrument A static **Active Electrical Energy Meter**
Type : MA105H, MA105H2E
Manufacturer's mark or name : KAIFA
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T10805 revision 6;
- Documentation folder T10805-7.

Valid until 19 August 2026
Initially issued 19 August 2016

Remarks This revision replaces the earlier version(s), including its documentation
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
05 September 2025

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

