

# EU-type examination certificate

Number **T11019** revision 6  
Project number 4056748  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Inepro Metering BV  
Pondweg 7  
2153 PK Nieuw-Vennep  
The Netherlands

Authorised  
representative

Inepro Metering BV  
Pondweg 7  
2153 PK Nieuw-Vennep  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : PRO2-S / PRO2-2T / PRO2-Mb / PRO2-Mod

Manufacturer's mark or name : Inepro

Reference voltage : 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11019 revision 6;
- Documentation folder T11019-6.

Valid until

24 April 2027

Initially issued

24 April 2017

Remark

This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
12 February 20266

Certification Board