





Number T11147 revision 25 Project number 3828632 Page 1 of 1

Issued by NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.L

Via Ombrone, 2 00198 Roma

Italia

Measuring instrument A static Active Electrical Energy Meter

Type : GETIS

Manufacturer's mark or name Gridspertise

Reference voltage 3x230/400 V

3x127/220 ... 3x230/400 V

Reference current

Destined for the measurement of electrical energy, in a

- three-phase four-wire network

Accuracy class A or B **Environment classes** M1 / E2

Temperature range -25 °C / +55 °C

Further properties are described in the annexes:

- Description T11147 revision 25;

- Documentation folder T11147-8.

Valid until 23 November 2027

Initially issued 23 November 2017

Remark This revision replaces the earlier versions, expect its documentation folder.

NMi Certin B.V., Notified Body number 0122

Issuing Authority

05 June 2024 **Certification Board**

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party

liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of

Reproduction of the complete document only is permitted.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T+31 88 636 2332 certin@nmi.nl www.nmi.nl

this certificate.