

# EU-type examination certificate

Number **T11169** revision 13  
Project number 3945664  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect  
to conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis + Gyr A.E.  
78th km National Road Athens-Corinth  
GR-201 00, Corinth  
Greece

Measuring instrument A static **Active Electrical Energy Meter**

Type : E450 G3 IDIS (ZCXi1x0xQ S4)  
Manufacturer's mark or name : Landis + Gyr  
Reference voltage : 230 V  
Reference current : 5 A or 10 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : B or A  
Environment classes : M2 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11169 revision 13;
- Documentation folder T11169-3.

Valid until

1 September 2027

Initially issued

1 September 2017

Remarks

This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
23 April 2025

Certification Board

**NMi Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.