



EU-type examination certificate

Number **T11299** revision 5
Project number 3746577
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect
to conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

SE1P
Pondweg 7
2153 PK Nieuw-Vennep
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : iEM2055
Manufacturer's mark or name : SE1P
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11299 revision 5;
- Documentation folder T11299-4.

Valid until

13 April 2028

Initially issued

13 April 2018

Remark

This revision replaces the earlier versions, including its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
14 March 2025

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)
ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

