





Number T11301 revision 4 Project number 3919719 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Shenzhen Kaifa Technology (Chengdu) Co., Ltd.

No. 99 Tianquan Rd.,

Hi-Tech Development Zone

Chenadu 611731

P.R. China

Measuring instrument A static Active Electrical Energy Meter

MA105H2CNL or MA105 Type

KAIFA Manufacturer's mark or name

Reference voltage 230 V Reference current 5 A

Destined for the measurement of electrical energy, in a

- single-phase two-wire network

Accuracy class B or A **Environment classes** M1 / E2 Temperature range -25 °C / +70 °C

Further properties are described in the annexes:

- Description T11301 revision 4; - Documentation folder T11301-5.

29 May 2028

Initially issued 29 May 2018

This revision replaces the earlier versions, including its documentation Remark

folder.

Issuing Authority

Valid until

NMi Certin B.V., Notified Body number 0122

25 March 2025

Certification Board

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.







www.nmi.nl

