





Number T12106 revision 7 Project number 3942484 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Shenzhen Kaifa Technology (Chengdu) Co., Ltd.

No. 99 Tianquan Rd.,

Hi-Tech Development Zone

Chengdu 611731

P.R. China

Measuring instrument A static Active Electrical Energy Meter

MA309M

Manufacturer's mark or name Shenzhen Kaifa Technology

(Chengdu) Co., Ltd.

Reference voltage 3x240/415 V or 3x230/400 V Reference current 20 A or 10 A or 5 A (DC)

5 A (CT)

Destined for the measurement of electrical energy, in a

- three-phase four-wire network

Accuracy class A or B (DC)

B or C (CT)

Environment classes M2 / E2 or M1 / E2 -40 °C / +70 °C Temperature range

Further properties are described in the annexes:

- Description T12106 revision 7;

- Documentation folder T12106-6.

Valid until 17 June 2031

Initially issued 17 June 2021

This revision replaces previous revisions, including its documentation folder. Remark

Issuing Authority

NMi Certin B.V., Notified Body number 0122 8 April 2025

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

