



EU-type examination certificate

Number **T12229** revision 6
Project number 4056748
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer

Inepro Metering BV
Pondweg 7
2153 PK Nieuw Vennep
The Netherlands

Measuring instrument

A static **Active Electrical Energy Meter**

Type : 2PU CT

Manufacturer's mark or name : Inepro

Reference voltage : 230V; 3x230/400 V

Reference current : 1 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12229 revision 6;
- Documentation folder T12229-5.

Valid until

15 October 2031

Initially issued

15 October 2021

Remark

This revision replaces previous revisions, excluding its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
12 February 2026

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

RvA C 601