

EU-type examination certificate

Number **T12491** revision 1
Project number 3912638
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect
to conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

JHB Energy B.V.
Burgemeester Burgerslaan 40
5245 NH Rosmalen
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : IQ0102080m1
Manufacturer's mark or name : KWHIQ
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B or A
Environment classes : M1 / E2
Temperature range : -25 °C / +70 °C

Further properties are described in the annexes:

- Description T12491 revision 1;
- Documentation folder T12491-2.

Valid until

12 December 2032

Initially issued

12 December 2022

Remark

This revision replaces the earlier version, including its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
3 April 2025

Certification Board