



EU-type examination certificate

Number **T12698** revision 5
Project number 3987416
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised
Representative

Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument **A static Poly Phase Electricity Meter**

Type : E360 AM3D...I2

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x230/400 V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase-four-wire network
- two-phase-three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -10 °C / +70 °C

Further properties are described in the annexes:

- Description T12698 revision 5;
- Documentation folder T12698-2.

Valid until

1 February 2034

Initially issued

1 February 2024

Remark

This revision replaces the earlier versions, except for its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
07 October 2025

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

