



EU-type examination certificate

Number **T12775** revision 1
Project number 3904449
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Eastron Europe Limited
Suite 20 Cornwallis House, Howard Chase
Basildon SS14 3BB
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM54-DM

Manufacturer's mark or name : Eastron

Reference voltage : 3x230/400 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
- single-phase three-wire network
- three-phase four-wire network

Accuracy class : A or B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12775 revision 1;
- Documentation folder T12775-1.

Valid until

18 July 2034

Initially issued

18 July 2024

Remark

This revision replaces the previous version, with exceptions of the
documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
13 October 2025

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)
ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

