

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Eastron Europe Limited  
Suite 20 Cornwallis House, Howard Chase  
Basildon SS14 3BB  
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM230-CB  
Manufacturer's mark or name : Eastron  
Reference voltage : 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T12830 revision 0;  
- Documentation folder T12830-1.

Valid until 18 July 2034

Initially issued 18 July 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
18 July 2024

Certification Board