



# EU-type examination certificate



Number **T12905** revision 1

Project number 3889552

Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect  
to conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Itron Indonesia - PT Mecoindo  
EJIP Plot 6B-2 - Cikarang Selatan Bekasi  
17550 Jawa Barat  
Indonesia

Measuring instrument **A static Active Electrical Energy Meter**

Type	:	Riva T
Manufacturer's mark or name	:	Itron Indonesia – PT Mecoindo
Reference voltage	:	3x220/380 , 3x230/400 , 3x240/415
Reference current	:	5 A
Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network
Accuracy class	:	A or B
Environment classes	:	M1 / E2
Temperature range	:	-40 °C / +55 °C

Further properties are described in the annexes:

- Description T12905 revision 1;
- Documentation folder T12905-2.

Valid until

14 August 2035

Initially issued

14 August 2025

Remark

This revision replaces the earlier version, including its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
10 February 2026

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certain@nmi.nl](mailto:certain@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at <http://ec.europa.eu/growth/tools-databases/hando/>

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

PRODUCTS  
RvA C 681