

EU-type examination certificate

Number **T12909** revision 1
Project number 3894315
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Gridspertise Srl
Via Ombrone 2
00198 Roma
Italia

Measuring instrument A static **Active Electrical Energy Meter**

Type : Gridspertise
Manufacturer's mark or name : Globy-T, Globy-S
Reference voltage : Globy-T: 3x230/400 V; 3x240/415 V
Globy-S: 3x120/208 V; 3x230/400 V;
3x240/415 V
Reference current : 5 A (direct-connected meter)
1 A (transformer-operated meter)
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12909 revision 1;
- Documentation folder T12909-2.

Valid until

14 February 2035

Initially issued

14 February 2025

Remark

This revision replaces the earlier version, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
20 March 2025

Certification Board