

EU-type examination certificate

Number **T12909** revision 3
Project number 3857969
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Gridspertise Srl
Via Ombrone 2
00198 Roma
Italia

Measuring instrument

A static **Active Electrical Energy Meter**

Type : Gridspertise

Manufacturer's mark or name : Globy-T, Globy-S

Reference voltage : Globy-T: 3x230/400 V...3x240/415 V
Globy-S: 3x120/208 V...3x230/400 V;
3x240/415 V

Reference current : Globy-T: 5 A
Globy-S: 1 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : Globy-T: A or B
Globy-S: A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12909 revision 3;
- Documentation folder T12909-3.

Valid until

14 February 2035

Initially issued

14 February 2025

Remarks

This revision replaces the earlier versions, excluding its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
26 June 2025

Certification Board