



# EU-type examination certificate

Number **T12940** revision 1  
Project number 4034755  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Shenzhen Kaifa Technology (Chengdu) Co., Ltd.  
No. 99 Tianquan Rd.  
Hi-Tech Development Zone  
Chengdu 611731  
P.R. China

Measuring instrument A static **Active Electrical Energy Meter**

Type : MA110M

Manufacturer's mark or name : KAIFA

Reference voltage : 230V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12940 revision 1;
- Documentation folder T12940-2.

Valid until

19 December 2034

Initially issued

19 December 2024

Remark

This revision replaces the earlier version(s), including its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
10 February 2026

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

